

MEMORANDUM

TO: CITY OF SUGAR LAND PLAN REVIEWER
FROM: NICHOLAS BADKE
SUBJECT: OPTIMUM CARE- SUGAR LAND, TX
DATE: 2014-12-11

Dear Sir/Madam,

PVC piping for use as sanitary waste and vent piping is acceptable below slab and in all areas above slab not used as a return air plenum.

Romex cabling has been approved by the owner for use in his/her facility. We have no reservation about the use of the city approved cabling as requested by the owner.

Please let me know of any questions.

Thanks,



Nicholas Badke
Project Manager